

City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2047693 Permit #: 00171-2024ABN Request Rec'd: 02/14/2024 Approval Date: 02/14/2024 Permit Expires: 08/14/2024

<u>Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Thresholds

4101 N Ravenswood Ave Chicago, IL 60613

Contact: Daniel Lach 708/307-4209

FACILITY

- name and address where tanks are located:

Thresholds 734 W 47th Street Chicago, IL 60609 Cook County

Contact: Daniel Lach 708/307-4209

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
3	1,100	Unknown	Inert material mixed with portland cement	Tank and associated piping to be removed.

Explanation of Waiver for Abandonment

UST has waterline on two sides of the tank and a sewer line running across the west side of the tank and cannot safely be removed.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

RW Collins Company 7225 West 66th Street Chicago, IL 60638 Contact Person: Lisa Kruse Phone: 708/308-8217

Email: ademauro@rwcollins.com

Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Sean Keane