



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2025043  
Permit #: 00173-2024LIN  
Request Rec'd: 02/14/2024  
Approval Date: 02/15/2024  
Permit Expires: 08/15/2024

**Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances**

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. **THIS PERMIT IS FOR THE INTERIOR INSPECTION OF THE EXISTING LINING ONLY! NO REPAIRING, UPGRADING, OR INTERIOR LINING IS AUTHORIZED WITH THIS PERMIT.**

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Elite Car Wash 823 N Western Ave Chicago, IL 60622 Cook County Contact: Rick Scali 773/342-7977	<b>FACILITY</b> - name and address where tanks are located: Elite Car Wash 823 N. Western Chicago, IL 60622 Cook County Contact: Rick Scali 312/342-7977
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status	Manway
3	Gasoline - Regular	10,000	Currently in use	Federal	Install

**Summary of Work**

Cut, bust, and excavate area over tank. Purge, clean and inspect the internal lining of the following tank in accordance with State of Illinois 175 and API-1631 regulations. Furnish and install (1) 20" manway on tank. Install 36" culvert, backfill and recover with new reinforced concrete and at grade access manway.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Armor Shield of Wisconsin 3965 Hillside Road Slinger, WI 53086	Contact Person: Clayton Bennett Phone: 262/623-0300 Email: paula@armorshieldus.com Contractor License # IL1707 Exp. 4/18/2024

Sincerely,

Sean Keane