



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Extended**

**FOR OFFICE USE ONLY**

Facility #: 2023271  
Permit #: 00918-2023UPG  
Request Rec'd: 08/17/2023  
Approval Date: 08/18/2023 DS  
Extension Date: 02/15/2024  
Permit Expires: 08/20/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: US Department of Energy 9800 S. Cass Ave. Lemont, IL 60439 Du Page County Contact: Kaushik Joshi 630/252-4226	<b>FACILITY</b> - name and address where tanks are located: Argonne National Laboratory 9700 S. Cass Ave. Argonne, IL 60439 Du Page County Contact: Mark Pfeiffer 630/252-6408
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
62	E85	10,000	Currently in use	Federal

**Tank 62 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

**Dispensers on the Permit**

Dispenser	Action
3/4	Sump / Sensors Changing

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

**Summary of Work**

Replacing existing UDC at E-85 dispenser  
product piping will be cut back just far enough to install new dispenser  
New flex connector to be installed  
Existing sensor with positive shut down will be re-used

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

*Daniel G. Starks*

Daniel Starks