



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

<b>FOR OFFICE USE ONLY</b>	
Facility #:	4043622
Permit #:	00063-2024UPG
Request Rec'd:	01/18/2024
Amended Date:	02/16/2024 DS
Approval Date:	01/18/2024 DS
Permit Expires:	07/18/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909 Knox County Contact: Joey Cupp 865/588-7488	<b>FACILITY</b> - name and address where tanks are located: Pilot Travel Center #368 4030 E. Boyd Road Decatur, IL 62526 Macon County Contact: Leigh West 865/588-7488
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	20,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping	Replacing - Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX
Piping	Flex Connector Steel	Replacing - Piping - Flex Connector Steel
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing

**Summary of Work**

UPGRADING TANK 5 TO B99 COMPATIBLE.  
 INSTALLING B99 APPROVED OVERFILL TUBE OPW 71SO-410CB AND SWIVEL ADAPTOR OPW 61SALP-1020-EVR.  
 INSTALLING A NEW TANK SUMP AND DOUBLE WALL FIBERGLASS PIPING.

**Special Contingencies**

**Amendment Reason:**

amend permit to add a sump and move piping then convert the tank to b99

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: 314/772-4501  
Email: testing@neumayerequipment.com  
Contractor License # IL1502 Exp. 3/26/2024

Sincerely,

  
\_\_\_\_\_

Daniel Starks