



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2010522
Permit #: 00184-2024UPG
Request Rec'd: 02/16/2024
Approval Date: 02/16/2024 DS
Permit Expires: 08/16/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: 802 West Palatine, LLC 1983 Route 52 Hopewell Junction, NY 12533 (None) County Contact: Patty Garcia 845/765-8507 | FACILITY - name and address where tanks are located: 802 West Palatine, LLC 802 W. Palatine Road Palatine, IL 60067 Cook County Contact: Abraham Sallah 347/499-3835 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 4 | Diesel Fuel | 10,000 | Currently in use | Federal |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Replacing - Leak Detect - Piping - Stand Alone Sump Sensor |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-------------------------|
| 7/8 | Sump / Sensors Changing |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Stand Alone Sump Sensor |

Summary of Work

Re: NOV E0020240216

Tank #4 has double-wall fiberglass pipe. Replacing existing standalone sensors in tank sump and under dispenser 7/8 with Veeder-Root 794380-208 non-discriminating sump sensors. The UDC sensor will be programmed to shut down all three products at the site (RUL, PUL, DSL) and the tank sump sensor on Tank #4 will only shut down Tank #4.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: jim.veverka@bkequip.com
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Daniel Starks