



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2021414
Permit #: 00185-2024CAT
Request Rec'd: 02/16/2024
Approval Date: 02/16/2024 DS
Permit Expires: 08/16/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 16658, Inc. 16658 Crawford Markham, IL 60426 Cook County Contact: Thomas Simon 847/409-1884	FACILITY - name and address where tanks are located: Josh Petro Food Mart 16658 Crawford Avenue Markham, IL 60478 Cook County Contact: Prakash Kuruvilla 708/333-7700
---	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	8,000	Currently in use	Federal
2	Gasoline - Regular	8,000	Currently in use	Federal
4	Gasoline - Premium	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Disp. 1/2 - Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp. 1/2
Corrosion Protection - Piping	Disp. 3/4 - Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp. 3/4

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Disp. 1/2 - Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp. 1/2
Corrosion Protection - Piping	Disp. 3/4 - Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp. 3/4

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Disp. 1/2 - Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp. 1/2
Corrosion Protection - Piping	Disp. 3/4 - Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - Disp. 3/4

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Install (1) 9lb anode in each dispenser 1/2 & 3/4 per NOV.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Protanic, LLC 658 North Progress Drive PO Box 80265 Saukville, WI 53080	Contact Person: Kylie Krombach Phone: 262/268-1150 Email: LeeH@protanicinc.com Contractor License # IL1413 Exp. 9/26/2024

Sincerely,



Daniel Starks