



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3023917
Permit #: 00192-2024UPG
Request Rec'd: 02/19/2024
Approval Date: 02/20/2024 DS
Permit Expires: 08/20/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Illinois Department of Corrections 600 Linwood Road P.O. Box 1327 Galesburg, IL 61401 Knox County Contact: Doug Sanford 309/343-4212Ext.281	FACILITY - name and address where tanks are located: Galesburg Correctional Center 600 Linwood Road Galesburg, IL 61401 Knox County Contact: Brian Ledbetter 309/343-4212Ext.281
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 2000	Replacing - Leak Detect - Tank - Vapor Monitoring
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor

Dispensers on the Permit

Dispenser	Action
1	Sump / Sensors Changing

Dispenser 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Not Installed UDC Sump	New

Summary of Work

Installing new pneumercator TMS 2000 for tank testing

Install new pneumercator sensors in existing tank and dispenser sumps for piping leak detection with positive shut down.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

Daniel G. Starks

Daniel Starks

For Office Use Only

Dispenser 1 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Review