

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2039910
Permit #: 00193-2024UPG
Request Rec'd: 02/20/2024
Approval Date:02/20/2024 DS
Permit Expires: 08/20/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

RDK Ventures, LLC

1100 Situs Court, Suite 100 Raleigh, NC 27606

Du Page County

Contact: Elizabeth Sauser 708/748-3496

FACILITY

- name and address where tanks are located:

Circle K #6792 25515 S. US 45 Monee, IL 60449 Will County

Contact: Sherri Lohrman 630/800-6065

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	20,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	North - Double Wall Spill Bucket	Replacing - Spill Contain Device - Double Wall Spill Bucket - North
Overfill Prevention Device	North - Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve - North
Piping	Other Steel Riser	New

Summary of Work

Installing new riser and replacing overspill and overfill on Tank $\#\ 1$ - North

Special Contingencies

Paniel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.

19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: 708/560-5590
Email: keith@andersonpump.com
Contractor License # IL002275 Exp. 5/21/2024

Sincerely,

Daniel Starks