



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 5020604  
Permit #: 00195-2024UPG  
Request Rec'd: 02/20/2024  
Approval Date: 02/20/2024 DS  
Permit Expires: 08/20/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231</p>	<p><b>FACILITY</b> - name and address where tanks are located: Casey's General Store #2937 1133 W. Jefferson Springfield, IL 62702 Sangamon County Contact: Jill Reams Widder 515/965-6238</p>
--	--

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Diesel Fuel	8,000	Currently in use	Federal

**Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New
Piping	Flex Connector Steel	New

**Summary of Work**

Installing a manifold under existing dispenser #13/14. The manifold will be installed under the shear valves and shear valves will be rigidly mounted to the UDC. Dispenser has an existing containment sump and sensor. Performing a precision line test after the installation.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Total Petroleum Service Company 2421 Washington Road Washington, IL 61571</p>	<p>Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2026</p>

Sincerely,

Daniel Starks