



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

Permit for Emergency Repair Request on 2/20/2024

FOR OFFICE USE ONLY
Facility #: 2007785
Permit #: 00204-2024UPG
Request Rec'd: 02/21/2024
Approval Date: 02/21/2024
Permit Expires: 03/06/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR TEN WORKING DAYS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: AT&T Corp. d/b/a Illinois Bell 308 S. Akard, Room 1700 Dallas, TX 75202 (None) County Contact: Chantel McMorris 800/566-9347	FACILITY - name and address where tanks are located: Beverly CO 1620 West 99th Street Chicago, IL 60643 Cook County Contact: Fountain Bud 313/874-8979
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	1,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Steel Single Wall Piping	Replacing - Piping - Steel Single Wall Piping

Summary of Work

Found leak in piping just outside the containment sump. Removed damaged section and install new. Pipe will be run back into the containment sump through existing chase.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: johnbu@restenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

Sean Keane