



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2013815
Permit #:	00210-2024UPG
Request Rec'd:	02/22/2024
Approval Date:	02/22/2024 DS
Permit Expires:	08/22/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Kirchoff Oil, Inc. 4200 Kirchoff Rolling Meadows, IL 60008 (None) County Contact: Mohammed Hussain 312/505-7272	FACILITY - name and address where tanks are located: 4200 Petro, LLC 4200 Kirchoff Rolling Meadows, IL 60008 Cook County Contact: Mohammed Hussian 312/505-7272
---	--

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
↳ Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

Summary of Work

DSL dispenser 1/2 was found to have an existing sump sensor that correctly operates as positive shutdown. UDC currently listed as sump sensor not installed not regulated. Permitting as having a positive shutdown UDC sensor.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/520-5292 Email: trevorh@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

Daniel Starks

<p>For Office Use Only</p>

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
↳ <i>Leak Detection - Piping</i>	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing