



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	2023831
Permit #:	00137-2024UPG
Request Rec'd:	02/05/2024
Amended Date:	02/22/2024 DS
Approval Date:	02/05/2024 DS
Permit Expires:	08/06/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: LB Five, LLC Series E 2401 W. US Highway 20 Suite 105 Pingree Grove, IL 60140 Kane County Contact: Joseph Lazar 847/344-2070	FACILITY - name and address where tanks are located: Oasis Lily Lake, Inc. 44W322 Highway 64 Lily Lake, IL 60151 Kane County Contact: Joseph Lazar 847/344-2070
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
12	Gasoline - Regular	20,000	Currently in use	Federal
13	Diesel Fuel	20,000	Currently in use	Federal
14	Gasoline - Premium	10,000	Currently in use	Federal
15	Diesel Fuel	5,000	Currently in use	Federal
16	E85	5,000	Currently in use	Federal

Tank 15 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
9/10	Sump / Sensors Changing
11/12	Sump / Sensors Changing
13/14	Sump / Sensors Changing
14S	Sump / Sensors Changing
15/16	Sump / Sensors Changing
17/18	Sump / Sensors Changing
19	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
<i>Leak Detection - Piping</i>	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
<i>Leak Detection - Piping</i>	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
<i>Leak Detection - Piping</i>	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
<i>Leak Detection - Piping</i>	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
<i>Leak Detection - Piping</i>	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 11/12 Equipment

Equipment Type	Permit Equipment	Action
<i>Leak Detection - Piping</i>	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 13/14 Equipment

Equipment Type	Permit Equipment	Action
<i>Leak Detection - Piping</i>	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 14S Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 15/16 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 17/18 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser 19 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump Bravo B-8000 Series	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Summary of Work

Replace electronic line leak with mechanical. Found sensors not connected to console and not programmed for positive shut off. Will connect and test all sensors.

Special Contingencies**Amendment Reason:**


Found sensors not connected to console and not programmed for positive shut off. Will connect and test all sensors.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: 708/243-9081
Email: steve@andersonpump.com
Contractor License # IL002275 Exp. 5/21/2024

Sincerely,



Daniel Starks