



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2013506
Permit #: 00220-2024UPG
Request Rec'd: 02/26/2024
Approval Date: 02/26/2024
Permit Expires: 03/08/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Central Gas Real Estate, LLC 1754 N. Central Ave. Chicago, IL 60639 Cook County Contact: Naif Alaskari 773/469-9040	FACILITY - name and address where tanks are located: Central Gas & Minimart 1754 N. Central Chicago, IL 60639 Cook County Contact: Naif Alaskari 773/836-7501
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	12,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX
Piping	Flex Connector Steel	New
Piping	Ball Valves	New


Summary of Work

There was a bad Bell x Male Ameron fitting in the RUL sump.
We cut the line inside the sump and installed a new Ameron Bell x Male fitting, 2" ball Valve and 2" x 12" SS Flex
Pressure tested and passed.
Purged line
Protanic Testing company will be on site on Tuesday Morning 2/27/2024 to Third Party test before line can be put back into service

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 708/243-0193 Email: dough@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive style with a horizontal line underneath the text.

Sean Keane