



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 1020390
Permit #: 00222-2024UPG
Request Rec'd: 02/27/2024
Approval Date: 02/27/2024 DS
Permit Expires: 08/27/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Noor Real Estate, LLC 8 Willow Bay Rd. South Barrington, IL 60010 (None) County Contact: Junaid Ahmed 630/290-9877	FACILITY - name and address where tanks are located: MKAM Gas & Food, Inc. 1100 East River Road Dixon, IL 61021 Lee County Contact: Almas Khan 331/684-5157
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	6,000	Out of service	Federal
2	Diesel Fuel	6,000	Out of service	Federal
3	Gasoline - Regular	10,000	Out of service	Federal
4	Gasoline - Regular	10,000	Out of service	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve	Removing
Overfill Prevention Device	Overfill Drop Tube Valve	Removing

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve	Removing
Overfill Prevention Device	Overfill Drop Tube Valve	Removing

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve	Removing
Overfill Prevention Device	Overfill Drop Tube Valve	Removing

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Ball Float Vent Valve	Removing
Overfill Prevention Device	Overfill Drop Tube Valve	Removing

Summary of Work

Overfill prevention drop tubes were not present during previously permitted work, installed non-overfill prevention drop tubes. Removed ball float valves.

Special Contingencies

NOTE: Site has existing overfill alarms

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: dj.white@bkequip.com
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Daniel Starks