

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2014514
Permit #: 00235-2024CAT
Request Rec'd: 02/29/2024
Approval Date:02/29/2024 DS
Permit Expires: 08/29/2024

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Sai Ram Properties, LLC 1550 Glen Rock Ave. Waukegan, IL 60085 (None) County

Contact: Seema Rani 478/550-6505

FACILITY

- name and address where tanks are located:

Sai Ram Properties, LLC 1550 Glen Rock Waukegan, IL 60085 Lake County

Contact: Rayam Popli 478/550-6505

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
11	Gasoline - Premium	10,000	Currently in use	Federal
12	Gasoline - Regular	10,000	Currently in use	Federal
13	Gasoline - Regular	10,000	Currently in use	Federal

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 13 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Regular 1 STP Sump has water and needs Anode Regular 2 STP Sump has water and needs Anode Premium STP has water and needs Anode. PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, LLC

658 North Progress Drive PO Box 80265 Saukville, WI 53080

Contact Person: Kylie Krombach Phone: 262/268-1150

Email: stuartr@protanicinc.com

Contractor License # IL1413 Exp. 9/26/2024

Sincerely, Daniel J. Starks

Daniel Starks