

City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2022764
Permit #: 00238-2024CAT
Request Rec'd: 02/06/2024
Approval Date: 03/01/2024
Permit Expires: 09/04/2024

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Chachy, Inc.

7550 N. Sheridan Rd. Chicago, IL 60626 (None) County

Contact: Jose Pinarkyil 773/465-3450

FACILITY

- name and address where tanks are located:

AJ Oil Group, Inc.

7550 North Sheridan Leah Mol, Inc. (Operator)

Chicago, IL 60626 Cook County

Contact: Jibit Joy 773/465-3450

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	E85	10,000	Currently in use	Federal
5	Gasoline - Premium	10,000	Currently in use	Federal
6	Gasoline - Regular	12,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	New

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	New

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	New

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Repair (3) cut cp wires for impressed current system and re-test.

PERSON, FIRM OR COMPANY PERFORMING WORK:

 $\label{eq:metro-environmental} \mbox{ Metro-Environmental Contractors, Inc. dba Metro-Tank \&$

Pump Company

1111 West Dundee Road Wheeling, IL 600903936 Contact Person: Warren Cherner

Phone: 847/465-4000

Email: warren@metrotank.com

Contractor License # IL102 Exp. 2/7/2026

Sincerely,

Sean Keane