



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov  
**Extended/Revised**

FOR OFFICE USE ONLY	
Facility #:	3039284
Permit #:	01092-2023UPG
Request Rec'd:	09/22/2023
Approval Date:	09/25/2023 DS
Extension Date:	01/24/2024
Revision Date:	03/04/2024 DS
Permit Expires:	09/26/2024

## Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.**

OWNER OF TANKS	FACILITY
- Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Elizabeth Sauser 210/692-2224	- name and address where tanks are located: Bigfoot #158 3016 West Farmington Road Peoria, IL 61604 Peoria County Contact: Julie Knott 309/672-1501

### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	15,000	Currently in use	Federal
2	Gasoline - Premium	15,000	Currently in use	Federal

### Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Flexible Double Wall Total Containment Enviroflex non-corrosive
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	Replacing - Leak Detect - Piping - Sump Sensor

### Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Flexible Double Wall Total Containment Enviroflex non-corrosive
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Dispensers on the Permit**

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
9/10	Sump / Sensors Changing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Dispenser 5/6 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Dispenser 7/8 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Dispenser 9/10 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Special Contingencies**

Replaced piping exceeds 20 feet or 50% of the total pipe run.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

**Revision Reason:**

Permit was changed to remove the spill buckets as the contractor did not replace them

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: 314/772-4501  
Email: testing@neumayerequipment.com  
Contractor License # IL1502 Exp. 3/26/2024

Sincerely,



Daniel Starks