

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2027733
Permit #: 00250-2024ENT
Request Rec'd: 03/02/2024
Approval Date:03/04/2024 DS
Permit Expires: 09/04/2024

# <u>Permit for HOTWORK / ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances</u>

Permission to enter underground storage tank(s) is hereby granted. Such tank entry must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

## THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Central DuPage Hospital 25 N. Winfield Road Winfield, IL 60199 Du Page County

Contact: Mike Schoewe 630/933-1600

**FACILITY** 

- name and address where tanks are located:

Central DuPage Hospital 25 N. Winfield Road Winfield, IL 60199 Du Page County

Contact: Jeff Wesley 630/933-1600

### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status	Manway
9	Diesel Fuel	20,000	Currently in use	Federal	Existing

### **Summary of Work**

Perform entry to determine repair method for interstitial leak.

## **Special Contingencies**

Daniel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Metro Environmental Contractors, Inc. dba Metro Tank &	Contact Person: Warren Cherner			
Pump Company	Phone: 847/465-4000			
1111 West Dundee Road	Email: warren@metrotank.com			
Wheeling, IL 600903936	Contractor License # IL102 Exp. 2/7/2026			

Sincerely,

Daniel Starks