

# City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2047713 Permit #: 00260-2024ABN Request Rec'd: 03/05/2024 Approval Date: 03/05/2024 Permit Expires: 09/06/2024

# <u>Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

## THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Robert Robinson 1432 Asbury Ave Evanston, IL 60201

Contact: Robert Robinson 847/493-9001

**FACILITY** 

- name and address where tanks are located:

Troscan 400 N. Oakley Blvd. Chicago, IL 60612 Cook County

Contact: Robert Robinson 847/493-9001

#### Tanks on the Permit

| Tank # | Capacity | Product     | Fill Material                             | Comments |
|--------|----------|-------------|---|----------|
| 1      | 1,000    | Heating Oil | Inert material mixed with portland cement |          |

## **Explanation of Waiver for Abandonment**

Abandonment of 1,000gallon Heating oil tank and lines due to <5' distance from building foundation

## **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:

RW Collins Company 7225 West 66th Street Chicago, IL 60638 Contact Person: Lisa Kruse Phone: 779/301-5966

Email: slucero@rwcollins.com

Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Sean Keane