



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2045118
Permit #: 00262-2024UPG
Request Rec'd: 03/06/2024
Approval Date: 03/06/2024 DS
Permit Expires: 09/06/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Robbin's Investment Inc. 4005 W. 135th St. Robbins, IL 60076 Cook County Contact: Jose Mohamed 708/389-0044	FACILITY - name and address where tanks are located: GoLo 4005 W. 135th St. Robbins, IL 60472 Cook County Contact: Mohamed Husain 708/389-0044
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
3	Gasoline - Premium	5,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350	Removing

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350	Removing

Summary of Work

Changing method of leak detection for Regular and Premium tanks to interstitial monitoring only.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Cardinal Compliance LLC 1058 National Parkway Schaumburg, IL 601734519	Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2025

Sincerely,

Daniel G. Starks

Daniel Starks