



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2047717  
Permit #: 00268-2024ABN  
Request Rec'd: 03/07/2024  
Approval Date: 03/08/2024  
Permit Expires: 09/10/2024

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Eyal Hagag 5070 N Kimberly Ave Suite C Chicago, IL 60630 Contact: Eyal Hagag 312/442-2277	<b>FACILITY</b> - name and address where tanks are located: 101 Kilbourn, LLC 1101 S. Kilbourn Ave. Chicago, IL 60624 Cook County Contact: Eyal Hagag 312/442-2277
--	--

**Tanks on the Permit**

Tank #	Capacity	Product	Fill Material	Comments
1	1,500	Unknown Oil-Solvent	Inert material mixed with portland cement	Tank located inside building will be cleaned and filled with slurry
2	1,500	Unknown Oil-Solvent	Inert material mixed with portland cement	Tank located inside building will be cleaned and filled with slurry
3	2,000	Unknown Oil-Solvent	Inert material mixed with portland cement	Tank located inside building will be cleaned and filled with slurry
4	2,000	Unknown Oil-Solvent	Inert material mixed with portland cement	Tank located inside building will be cleaned and filled with slurry
5	2,000	Unknown Oil-Solvent	Inert material mixed with portland cement	Tank located inside building will be cleaned and filled with slurry
6	2,000	Unknown Oil-Solvent	Inert material mixed with portland cement	Tank located inside building will be cleaned and filled with slurry
7	4,000	Unknown Oil-Solvent	Inert material mixed with portland cement	Tank located inside building will be cleaned and filled with slurry


**Explanation of Waiver for Abandonment**

Seven USTs are located inside the building and unable to be removed.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 708/308-8217 Email: ademauro@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive style with a horizontal line underneath the text.

Sean Keane