



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	6032440
Permit #:	00277-2024UPG
Request Rec'd:	03/11/2024
Approval Date:	03/11/2024 DS
Permit Expires:	09/11/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: QuikTrip Corporation 4705 South 129th East Ave. Tulsa, OK 74134 (None) County Contact: Victoria Hensley 918/994-3936	FACILITY - name and address where tanks are located: QuikTrip Store #694 2490 Troy Road Edwardsville, IL 62025 Madison County Contact: Sandy Schoenleber 618/656-0017
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	12,000	Currently in use	Federal
2	Gasoline - Regular	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Flexible Double Wall OPW Flexworks
Piping	Flex Connector Steel	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall OPW Flexworks	Replacing - Piping - Flexible Double Wall OPW Flexworks
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Summary of Work

We will replace the NL and premium line. this is more than 20% but less than 50% of the lines OPW flex pipe , new flexes hose and shear valves. OPW pipe 1.5" , omega flex hose, and then OPW 10p-0152 valves.

Special Contingencies

NOTE: Site has existing sumps and sensors with positive shutdown

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2024

Sincerely,

Daniel G. Starks

Daniel Starks