



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2017093
Permit #: 00279-2024UPG
Request Rec'd: 03/11/2024
Approval Date: 03/11/2024 DS
Permit Expires: 09/11/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Waleed Al-Far 2 N. Brainard Avenue La Grange, IL 60525 (None) County Contact: Waleed Al-Far 630/917-6010	FACILITY - name and address where tanks are located: Citgo La Grange 2 N. Brainard Avenue La Grange, IL 60525 Cook County Contact: Waleed Alfar 630/917-0101
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Premium	6,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Flexible Double Wall
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New

Summary of Work

Eliminating line manifold between the North & South RUL tanks / stp's. Product change where the South RUL tank becomes the PUL tank. Installing new Nupi DW Smartflex piping between South RUL tank and the 1st UDC / South dispenser island where we will tie into the existing DWFRP piping (inside UDC) to the other two UDC / dispenser islands.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 12/8/2024

Sincerely,

Daniel Starks