



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2023191  
Permit #: 00292-2024UPG  
Request Rec'd: 03/14/2024  
Approval Date: 03/17/2024 DS  
Permit Expires: 09/17/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Army Trail Swift Gasoline, Inc. 2101 W. Army Trail Road Addison, IL 60101 Du Page County Contact: Hemant Patel 847/331-1879	<b>FACILITY</b> - name and address where tanks are located: Army Trail Swift Gasoline, Inc. 2101 W. Army Trail Road Addison, IL 60101 Du Page County Contact: Justin Huge 847/331-1879
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	6,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

**Summary of Work**

Changing the Diesel spill bucket and Drop tube. Changing the riser and digdown is needed to the tank top.  
Adding the skirt for the Diesel STP sump to prevent water into the existing sump  
Changing the manhole for Diesel STP for the above repair  
Thank you  
Innovative Constructions

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Innovative Constructions Technology LLC 245 W Roosevelt Rd Building 4, Unit 28 West Chicago, IL 60185	Contact Person: Raju penumatsa Phone: 630/747-3404 Email: iconstructions81@gmail.com Contractor License # IL002453 Exp. 2/7/2026

Sincerely,

Daniel Starks