



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2036107  
Permit #: 00302-2024UPG  
Request Rec'd: 03/18/2024  
Approval Date: 03/18/2024  
Permit Expires: 09/18/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: 2001 Express Mini Mart, Inc. 1541 W. Garfield Blvd. Chicago, IL 60636 Cook County Contact: Khalil Abdullah 773/918-1178	<b>FACILITY</b> - name and address where tanks are located: Phillips 66 5501 S. Ashland Chicago, IL 60636 Cook County Contact: Khalil Abdullah 708/259-4539
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Premium	8,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	New
Piping	Other Steel Riser	New

**Summary of Work**

Replace spill container, riser and drop tube.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/243-9081 Email: steve@andersonpump.com Contractor License # IL002275 Exp. 5/21/2024

Sincerely,

Sean Keane