



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2042440
Permit #: 00303-2024UPG
Request Rec'd: 03/11/2024
Approval Date: 03/18/2024
Permit Expires: 09/19/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: United Airlines, Inc. 233 South Wacker Drive Chicago, IL 60606 Cook County Contact: Marianne Csaky 872/825-4480	FACILITY - name and address where tanks are located: United Airlines, Inc. 11555 W. Touhy - Chirr- Bldg. 912 Chicago, IL 60666 Cook County Contact: Glenn Heusmann 773/601-3544
---	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Fiberglass Non-Corrosive
Piping	Flexible Double Wall OmegaFlex DoubleTrac	Replacing - Piping - Fiberglass Double Wall A.O. Smith
Piping	Ball Valves	New

Summary of Work

Replacing existing pipe with new Omegaflex Doubletrac Pipe.
1" fuel supply and 1.5" Fuel overflow/return.
Ball valve in existing tank top sump.
Existing tank top sump to be reused. Now pipe entry boots will be installed.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: bob@crownetank.com Contractor License # IL002345 Exp. 5/16/2024

Sincerely,

Sean Keane