



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 6042984  
Permit #: 00304-2024UPG  
Request Rec'd: 03/19/2024  
Approval Date: 03/19/2024 DS  
Permit Expires: 09/19/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909 Knox County Contact: Joey Cupp 865/588-7488	<b>FACILITY</b> - name and address where tanks are located: Flying J Travel Plaza #642 140 Racehorse Drive Alorton, IL 62207 St. Clair County Contact: Gregory Jantz 865/588-7488
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	20,000	Currently in use	Federal
3	Diesel Fuel	20,000	Currently in use	Federal
4	Gasoline - Regular	20,000	Currently in use	Federal
5	Gasoline - Premium	12,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Summary of Work**

THE MAIN SHEAR VALVE ON DISPENSER 28 IS BROKEN.

**Special Contingencies**


**NOTE: A UDC must be installed if one doesn't already exist**

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: 314/772-4501  
Email: testing@neumayerequipment.com  
Contractor License # IL1502 Exp. 3/26/2024

Sincerely,



---

Daniel Starks