



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 2043206  
Permit #: 00029-2024UPG  
Request Rec'd: 01/09/2024  
Approval Date: 01/09/2024 DS  
Amended Date: 03/19/2024 DS  
Permit Expires: 07/09/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: RDK Ventures, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 Du Page County Contact: Elizabeth Sauser 708/748-3496	<b>FACILITY</b> - name and address where tanks are located: Circle K #6733 11900 S. Rt. 59 Plainfield, IL 60544 Will County Contact: Debbie Utter 630/800-6065
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	20,000	Currently in use	Federal
2	Gasoline - Premium	12,000	Currently in use	Federal
3	Diesel Fuel	8,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New

### Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

### Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

### Summary of Work

Replace TLS350 with TLS 450+. Replace plld with Dplld. Replace spill container, riser and drop tube on RUL and Premium.

### Special Contingencies

#### Amendment Reason:

Need to replace risers and spill containers on 2 tanks.

#### PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Ron Anderson  
Phone: 708/243-9081  
Email: [steve@andersonpump.com](mailto:steve@andersonpump.com)  
Contractor License # IL002275 Exp. 5/21/2024

Sincerely,



Daniel Starks