



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2024591
Permit #: 00324-2024UPG
Request Rec'd: 03/22/2024
Approval Date: 03/24/2024 DS
Permit Expires: 09/24/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| OWNER OF TANKS - Corporation, partnership, or other business entity: RDK Ventures, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 Du Page County Contact: Elizabeth Sauser 708/748-3496 | FACILITY - name and address where tanks are located: Circle K #6707 255 North Weber Bolingbrook, IL 60439 Will County Contact: Valentina Nikolla 812/379-9227 |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 4 | Gasoline - Regular | 20,000 | Currently in use | Federal |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|-------------------|--------|
| Piping | Other Steel Riser | New |

Summary of Work

Installing a new riser, vapor bucket, adapter & cap on Regular (#4) tank

Special Contingencies

| | |
|----------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448 | Contact Person: Ron Anderson Phone: 708/560-5590 Email: keith@andersonpump.com Contractor License # IL002275 Exp. 5/21/2024 |

Sincerely,

Daniel Starks