



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3018770
Permit #: 00326-2024CAT
Request Rec'd: 03/22/2024
Approval Date: 03/24/2024 DS
Permit Expires: 09/24/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Mann, LLC 1501 7th Avenue Rock Island, IL 61201 Rock Island County Contact: Pardeep Singh 309/786-7280	FACILITY - name and address where tanks are located: Star #1160 1501 7th Avenue Rock Island, IL 61201 Rock Island County Contact: Pardeep Singh 309/786-7280
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Premium	10,000	Currently in use	Federal
7	Gasoline - Regular	12,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	New

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	New

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Adding anodes To Gas UDC 1/2, 3/4, 5/6, 7/8, 9/10, 11/12

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Robert Schafer Phone: 563/529-8502 Email: rob@pipoeecoinc.com Contractor License # IL2034 Exp. 9/28/2024

Sincerely,

Daniel G. Starks

Daniel Starks