



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 6038973
Permit #: 00327-2024UPG
Request Rec'd: 03/22/2024
Approval Date: 03/24/2024 DS
Permit Expires: 09/24/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Martin & Bayley, Inc. P.O. Box 385 Carmi, IL 62821 White County Contact: Landon Bayley 618/382-2334Ext.248	FACILITY - name and address where tanks are located: Hucks #326 8795 Sasak Place Caseyville, IL 62232 St. Clair County Contact: Lincoln Rudolph 618/382-2334
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	20,000	Currently in use	Federal
2	Gasoline - Mid-grade	10,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal
4	Diesel Fuel	4,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Summary of Work

SHEAR VALVE ON DISPENSER 17/18 NEEDS TO BE REPLACED IT DOES NOT STOP FLOW OF FUEL.

Special Contingencies

NOTE: A UDC must be installed if not already existing

PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: 314/772-4501
Email: testing@neumayerequipment.com
Contractor License # IL1502 Exp. 3/26/2024

Sincerely,



Daniel Starks