



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	4043622
Permit #:	00064-2024ABN
Request Rec'd:	01/18/2024
Approval Date:	01/18/2024 DS
Amended Date:	03/25/2024 DS
Permit Expires:	07/18/2024

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909 Knox County Contact: Joey Cupp 865/588-7488	FACILITY - name and address where tanks are located: Pilot Travel Center #368 4030 E. Boyd Road Decatur, IL 62526 Macon County Contact: Leigh West 865/588-7488
--	--

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
3	20,000	B-99	Inert material mixed with portland cement	closing in place bio tank
4	20,000	Diesel Fuel	Inert material mixed with portland cement	CLOSING IN PLACE

Explanation of Waiver for Abandonment

WE ARE RECOMENDING ABANDONMENT IN PLACE DUE TO THIS TANK BEING IN PROXIMITY OF THE OTHER EXISTING ACTIVE TANKS AND PRODUCT LINES. THE LINES ARE IN THE SAME PROXIMITY OF THE LIVE DIESEL LINES AND WE HAVE THE POTENTIAL OF DAMAGING THE LIVE LINES. PLEASE SEE DRAWINGS ATTACHED.

AMENDING TO INCLUDE TANK 4 TO BE CLOSED IN PLACE

Special Contingencies

Amendment Reason:

AMENDING PERMIT TO INCLUDE CLOSING TANK 4 IN PLACE.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2024

Sincerely,

Daniel Starks