



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2007023  
Permit #: 00342-2024UPG  
Request Rec'd: 01/31/2024  
Approval Date: 03/27/2024  
Permit Expires: 09/27/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Standard Bank & Trust, Trust 17777 dated June 20, 2003 7560 S. Cottage Grove Chicago, IL 60619 Cook County Contact: Nasser Yafai 773/592-1223	<b>FACILITY</b> - name and address where tanks are located: 75th & Cottage Food & Gas, Inc. 7560 S. Cottage Grove Chicago, IL 60619 Cook County Contact: Hussain Yafai 718/844-0990
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	5,000	Out of service	Federal

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Fiberglass Double Wall
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump

**Summary of Work**

The Diesel isld will be replaced in the existing position. An E85 conversion will require the change of mechanical leak detector, STP, testing probe, overfill prevention drop tube, ball valve and shear valve and STP sump. Also the piping will be cut back 5 lf. and replaced to accommodate the new sump installation.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: jim.veverka@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

Sean Keane