



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2021139
Permit #:	00343-2024UPG
Request Rec'd:	03/27/2024
Approval Date:	03/27/2024 DS
Permit Expires:	09/27/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: True North Energy, LLC 10346 Brecksville Road Brecksville, OH 44141 (None) County Contact: David P. Nye 440/792-4200	FACILITY - name and address where tanks are located: True North Location 1952 251 S. Rt. 53 Addison, IL 60101 Du Page County Contact: Shailesh Patel 216/267-9336
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Premium	10,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket Remote Fill	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New

Summary of Work

Install new double wall remote fill overspill for the premium tank.

Special Contingencies

NOTE: After May 1, 2003, any new installation with a remote fill over 20 feet in length shall have interstitial monitoring and an audible and visible overfill alarm. Remote fills shall be sloped back to the tank. per section 175.445

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company 1111 West Dundee Road Wheeling, IL 600903936	Contact Person: Warren Cherner Phone: 847/465-4000 Email: warren@metrotank.com Contractor License # IL102 Exp. 2/7/2026

Sincerely,

Daniel Starks