

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 1024464
Permit #: 00345-2024UPG
Request Rec'd: 03/27/2024
Approval Date:03/27/2024 DS
Permit Expires: 09/27/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Louis A. Timp Trust

102 W. Main Street P.O. Box 396

Lena, IL 61048 (None) County

Contact: Amy Powers 815/369-4524

FACILITY

- name and address where tanks are located:

Louie's Trenching Service, Inc.

9720 Route 20 West Galena, IL 61036 Jo Daviess County

Contact: Becky Fisher 815/777-0865

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	10,000	Currently in use	Federal
4	Diesel Fuel	10,000	Currently in use	Federal
5	Diesel Fuel	10,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Replacing spill containments and overfill valves because they failed testing

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Central Petroleum Equipment Company

109 Terrace Dr.

Blue Grass, IA 52726

Contact Person: Roger Clark Phone: 563/381-5092

Email: rogercpec@revealed.net

Contractor License # IL345 Exp. 6/14/2024

Sincerely, Caniel J. Starks

Daniel Starks