



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2023171
Permit #: 00346-2024UPG
Request Rec'd: 03/27/2024
Approval Date: 03/28/2024
Permit Expires: 09/30/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Mohammed Zahir 2 W. 111th Street Chicago, IL 60628 Cook County Contact: Mohammed Zahir 773/548-8000	FACILITY - name and address where tanks are located: Roseland Marathon 2 West 111th Street Chicago, IL 60628 Cook County Contact: Mohammad Zahir 773/785-5587
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Removal of failed single wall spill bucket on premium tank and installation of OPW double wall spill bucket. Broom finished concrete and hydrostatic test on spill bucket. results will be submitted to OSFM

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
American Petroleum Solutions LLC 180 Forest Trail Oak Brook, IL 60523	Contact Person: Haibat Khan Phone: 909/312-9449 Email: apetro.office@gmail.com Contractor License # IL002454 Exp. 5/16/2024

Sincerely,

Sean Keane