



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-024688
Permit # 00884-2006REM
Request Rec'd 06/12/2006
Amended Date
Approval Date 6/19/2006 JC
Permit Expires 12/19/2006

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Westlake Christian Academy 275 S. Lake Street Grayslake, IL 60030 Contact:	(2) FACILITY - name and address where tanks are located: Westlake Christian Academy 275 S. Lake Street Grayslake, Lake Co., IL Contact: Anderson David M (708) 223-0065
--	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed:* (TK # 1) - 10,000 gallons
- (b) *Product stored in each tank:* (TK # 1) - Heating Oil
- (c) *Reason of tanks being removed:* No longer needed
- (d) *If tank(s) is leaking, indicate IEMA incident number:*
- (e) *Date each tank was last used:* (TK # 1) - 06/01/1980

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** This permit is for tank #1 rather than tank #2 (tank #2 was entered in error and does not exist). The permit application that was sent in showed a 12,000 gallon pre-74 tank to be removed. The file shows the registration of a 1000 gallon tank last used in 1980; consequently, we assumed the 12000 gallon tank on the permit application was a second tank. Upon further investigation from Sue Dwyer of the site, we have come to the conclusion that tank #2 is actually tank #1. No evidence of a second tank has been found.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
_____	Contact Person: _____
17494 W. Hickory Lane	Phone: _____
_____	Contractor Registration # _____ Exp. _____

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)