

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 2038945
Permit #: 00388-2024UPG
Request Rec'd: 04/08/2024
Approval Date:04/08/2024 DS
Permit Expires: 10/08/2024

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Thorntons, LLC

2600 James Thornton Way Louisville, KY 40245

Jefferson County

Contact: Maggie Seaugh 502/425-8022

**FACILITY** 

- name and address where tanks are located:

Thornton Oil #129 2201 N. Green Bay Rd. Waukegan, IL 60087

Lake County

Contact: Laura Ohm 502/425-8022

### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Diesel Fuel	6,000	Currently in use	Federal
5	Diesel Fuel	6,000	Currently in use	Federal

### **Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
► Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New

## **Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Lask Dataction Dining	Sump Sensor with positive shutdown	New
► Leak Detection - Piping	in Single Wall STP/Tanktop Sump	ivew

#### **Summary of Work**

Adding sump sensors to the STP sumps

Janiel J. Starke

## **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:			
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/606-0996 Email: nickb@rstenstrom.com Contractor License # IL1890 Exp. 3/7/2026		

Sincerely,

**Daniel Starks**