



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2025625  
Permit #: 00396-2024ABN  
Request Rec'd: 04/08/2024  
Approval Date: 04/08/2024 DS  
Permit Expires: 10/08/2024

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Star Bright Investments, LLC 8060 Lawndale Ave. Skokie, IL 60076 Cook County Contact: Nasir Yaqoob 847/679-5398	<b>FACILITY</b> - name and address where tanks are located: Mobil 7169 N. Crawford Lincolnwood, IL 60712 Cook County Contact: Andrei Orban 847/322-6864
---	---

**Tanks on the Permit For Piping Only**

Tank #	Capacity	Product	Fill Material	Comments
2	10,000	Diesel Fuel	Piping Capped Off	

**Explanation of Waiver for Abandonment**

A leak was discovered in the existing Diesel line. Attached site plan will show that the tee was eliminated. The Diesel will only be available at the dispenser near the tank. Branches off of the old tee will be capped. IEMA Number is H2024-023 (Unable to enter the number in the below field)

**Location of Piping Being Abandoned**

**NOTE: Piping to be abandoned shares a trench with active piping**

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 12/17/2025

Sincerely,



Daniel Starks