

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 6038947
Permit #: 00401-2024UPG
Request Rec'd: 04/09/2024
Approval Date:04/09/2024 DS
Permit Expires: 10/09/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Gateway FS, Inc. P.O. Box 100 Red Bud, IL 62278 Randolph County

Contact: Greg Birchler 618/282-3454

FACILITY

- name and address where tanks are located:

Gateway FS, Inc. - Fuel 24

Highway 155 East

Prairie du Rocher, IL 62277

Randolph County

Contact: Dylan Bivevenue 618/282-3454

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 1001
L eak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 1001
\ eak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
4 satellite	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
►Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
►Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Dispenser 4 satellite Equipment

Equipment Type	Permit Equipment	Action
►Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Summary of Work

Replacing the Incon TS 1001 with an Evo 600 with Scald. Replacing all sump sensors and all probes. I have attached the sales quotation that has been signed by the customer. Equipment has been recieved awaiting permit approval by OSFM for installation.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:		
Mid-South Steel Products, Inc. 2071 Corporate Circle Drive PO Box 277 Cape Girardeau, MO 63703	Contact Person: Billy Thorne Phone: 573/275-3010 Email: billy@midsouthsteel.com Contractor License # IL1194 Exp. 8/17/2024	

Sincerely, Daniel J. Starks

Daniel Starks