



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2024878
Permit #: 00406-2024UPG
Request Rec'd: 04/10/2024
Approval Date: 04/10/2024 DS
Permit Expires: 10/10/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: H & M Group 1 12659 S. Ashland Ave. Calumet Park, IL 60827 Cook County Contact: Mohamed Ali 708/945-6604 | FACILITY - name and address where tanks are located: Amstar 12659 S. Ashland Ave. Calumet Park, IL 60827 Cook County Contact: Mohamed Ali 708/945-6604 |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 8,000 | Currently in use | Federal |
| 2 | Gasoline - Regular | 8,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
| Piping | Shear Valves | New |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|------------------|--------|
| Piping | Shear Valves | New |

Summary of Work

The has a manifolded line in dispenser 5/6 UDC that needed a double poppet shear valve according to OSFM inspector so replacing the shae valve

Special Contingencies

| | |
|--|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504 | Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025 |

Sincerely,

Daniel Starks