



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 1024387  
Permit #: 00408-2024CAT  
Request Rec'd: 04/11/2024  
Approval Date: 04/11/2024 DS  
Permit Expires: 10/11/2024

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Loma Investments, Inc. 4318 Hammersmith Lane Glenview, IL 60026 (None) County Contact: Cyril John 224/717-0376	<b>FACILITY</b> - name and address where tanks are located: Riverside Fuel, Inc. 7924 North Alpine Road Loves Park, IL 61111 Winnebago County Contact: Cyril John 224/717-0376
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Out of service	Federal
2	Gasoline - Regular	10,000	Out of service	Federal
3	Gasoline - Premium	10,000	Out of service	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - STIP3 Cathodic Protection with Dielectric Coating
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**


**Special Contingencies**

**Summary of Work**

CP Sac Anode repair on 3 tanks and 3 lines (Reg N, Reg S, Pre) site will need drillers and GPR private radar. Adding new sac  
17# anodes  
any questions please call me Frank Grebas

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Protanic, LLC 658 North Progress Drive PO Box 80265 Saukville, WI 53080	Contact Person: Kylie Krombach Phone: 262/268-1150 Email: frankg@protanicinc.com Contractor License # IL1413 Exp. 3/15/2026

Sincerely,

  
\_\_\_\_\_

Daniel Starks