



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2013986  
Permit #: 00418-2024ABN  
Request Rec'd: 03/29/2024  
Approval Date: 04/15/2024 DS  
Permit Expires: 10/16/2024

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Borden Chemical Inc 180 E Broad St Columbus, OH 43215 (None) County Contact: Krause Jeffrey 630/575-5705	<b>FACILITY</b> - name and address where tanks are located: Borden Chemical Inc 1401 S Circle Ave Forest Park, IL 60130 Cook County Contact: Jeff Krause 630/575-5705
--	---

**Tanks on the Permit**

Tank #	Capacity	Product	Fill Material	Comments
61	20,000	Methylene Diphenyl Diisocyanate	Inert material mixed with portland cement	
62	20,000	Methylene Diphenyl Diisocyanate	Inert material mixed with portland cement	
63	20,000	Methylene Diphenyl Diisocyanate	Inert material mixed with portland cement	
64	20,000	Hazardous Substance	Inert material mixed with portland cement	
65	20,000	Naptha	Inert material mixed with portland cement	
66	12,000	Naptha	Inert material mixed with portland cement	
67	12,000	Hazardous Substance	Inert material mixed with portland cement	
68	12,000	Kerosene	Inert material mixed with portland cement	

**Explanation of Waiver for Abandonment**

Abandonment of 8 USTs and all asociated tank piping due to location in basement inside warehouse building

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Daniel Starks