



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 5021667  
Permit #: 00420-2024REM  
Request Rec'd: 04/15/2024  
Approval Date: 04/15/2024 DS  
Permit Expires: 10/17/2024

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Moto, Inc. 721 W. Main Street Belleville, IL 62222 St. Clair County Contact: Shane Maxey 616/233-6754	<b>FACILITY</b> - name and address where tanks are located: Hillsboro Motomart 601 S. Main Hillsboro, IL 62049 Montgomery County Contact: Gail Phillips 618/233-6754
---	--

**IEMA Number**  
2024-0309

**Tanks on the Permit**

Tank #	Capacity	Product	Last Used Date
5	8,000	Gasoline - Premium	
6	6,000	B-11	

**Summary of Work**

The Prem and Diesel tanks, product lines and vent lines will be removed. The existing UL tank will remain in use. The UL product lines will be removed and the UL vent line will remain in use. New Premium and Diesel tanks will be installed with new product lines, vent lines and new UL product lines under a separate install permit.

**Special Contingencies**

The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/267-1231 Email: terrys@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,

*Daniel G. Starks*

Daniel Starks