

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 1038235
Permit #: 00427-2024CAT
Request Rec'd: 04/17/2024
Approval Date:04/17/2024 DS
Permit Expires: 10/17/2024

# <u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

Corporation, partnership, or other business entity:
 Voluntary Action Center of Dekalb County
 1606 Bethany Road
 Sycamore, IL 60178
 (None) County

Contact: Ellen Rogers 815/758-3932

**FACILITY** 

- name and address where tanks are located: Voluntary Action Center of Dekalb County 1606 Bethany Road

Sycamore, IL 60178 De Kalb County

Contact: Ellen Rogers 815/758-3932

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

### **Tank 1 Equipment**

<b>Equipment Type</b>	Permit Equipment	Action
Corrosion Protection - Piping		Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection - STP

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

## **Special Contingencies**

#### **Summary of Work**

Replacing depleted anodes on piping in STP Sump.

Daniel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Cardinal Compliance LLC 1058 National Parkway Schaumburg, IL 601734519	Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2025			

Sincerely,

**Daniel Starks**