

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, IL 62703

217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov
 FOR OFFICE USE ONLY

 Facility #:
 2011055

 Permit #:
 00434-2024CAT

 Request Rec'd:
 04/06/2024

 Approval Date:04/18/2024 DS
 Permit Expires:

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of</u> <u>Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| OWNER OF TANKS | FACILITY |
|---|---|
| - Corporation, partnership, or other business entity: | - name and address where tanks are located: |
| Dharni Gas and Food, LLC | Dharni Gas and Food, LLC |
| 830 Main Street | 830 Main Street |
| Antioch, IL 60002 | Antioch, IL 60002 |
| Lake County | Lake County |
| Contact: Satwant Dharni 269/903-8188 | Contact: Satwant Dharni 269/903-8188 |

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|-------------------------|
| 1 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 2 | Gasoline - Premium | 10,000 | Currently in use | Federal |
| 4 | Kerosene | 4,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|------------------------|----------------------------|---|
| Corrosion Protection - | Impressed Current Cathodic | Replacing - Corrosion Prot - Tank - Impressed Current |
| Tank | Protection | Cathodic Protection |
| Corrosion Protection - | Impressed Current Cathodic | Replacing - Corrosion Prot - Piping - Impressed Current |
| Piping | Protection | Cathodic Protection |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|------------------------|----------------------------|---|
| Corrosion Protection - | Impressed Current Cathodic | Replacing - Corrosion Prot - Tank - Impressed Current |
| Tank | Protection | Cathodic Protection |
| Corrosion Protection - | Impressed Current Cathodic | Replacing - Corrosion Prot - Piping - Impressed Current |
| Piping | Protection | Cathodic Protection |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|------------------------|----------------------------|---|
| Corrosion Protection - | Impressed Current Cathodic | Replacing - Corrosion Prot - Tank - Impressed Current |
| Tank | Protection | Cathodic Protection |
| Corrosion Protection - | Impressed Current Cathodic | Replacing - Corrosion Prot - Piping - Impressed Current |
| Piping | Protection | Cathodic Protection |

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Installing new wires to (4) existing tank and piping anodes. All existing anodes are existing to remain.

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|--|
| Metro Environmental Contractors, Inc. dba Metro Tank & | Contact Person: Warren Cherner |
| Pump Company | Phone: 847/465-4000 |
| 1111 West Dundee Road | Email: warren@metrotank.com |
| Wheeling, IL 600903936 | Contractor License # IL102 Exp. 2/7/2026 |

Sincerely,

Daniel J. Starks

Daniel Starks