



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 1014530  
Permit #: 00442-2024UPG  
Request Rec'd: 04/19/2024  
Approval Date: 04/21/2024 DS  
Permit Expires: 10/22/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: J I Corporation 412 Wedgewood Lane Belvidere, IL 61008 Boone County Contact: Jamal Chaudary 815/544-0706	<b>FACILITY</b> - name and address where tanks are located: First Stop Mart #2 171 South Appleton Belvidere, IL 61008 Boone County Contact: Aousaf Chaudaary 815/744-0706
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Premium	8,000	Currently in use	Federal
6	Gasoline - Regular	15,000	Currently in use	Federal

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Summary of Work**

The RUL and PUL shear valves are damaged (arms broken) so replacing both the shear valves in Dispenser 3/4

**Special Contingencies**

**NOTE: UDC must be installed if not already existing**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025

Sincerely,



Daniel Starks