

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2041162
Permit #: 00456-2024UPG
Request Rec'd: 04/23/2024
Approval Date:04/23/2024 DS
Permit Expires: 10/23/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

FACILITY

OWNER OF TANKS

- Corporation, partnership, or other business entity:

GPM Midwest, LLC

8565 Magellan Pkwy, Ste. 400

Contact: Chad Fluck 520/663-6184

Richmond, VA 23227

(None) County

Bensenville Fuel Mark

1188 W. Foster Ave. Bensenville, IL 60106

Du Page County

Contact: Maria Dewitt 765/242-6664

- name and address where tanks are located:

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	15,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

Summary of Work

This permit is to replace expired permit # 00985-2023UPG Replacing leaking flex connector under dispenser 7/8

Special Contingencies

2422 Center Street

Rockford, IL 61108

NOTE: UDC must be installed if one doesn't already exist

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group

Vaniel J. Starke

Contact Person: Robert Stenstrom

Phone: 815/520-5292

Email: trevorh@rstenstrom.com

Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel Starks