



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2006921
Permit #: 00464-2024UPG
Request Rec'd: 04/25/2024
Approval Date: 04/26/2024 SB
Permit Expires: 10/28/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: PBBB, LLC 8702 S. 88th Avenue Hickory Hills, IL 60457 Cook County Contact: Jills Mathew 708/430-0277	FACILITY - name and address where tanks are located: Hickory Shell 8702 S. 88th Ave. Cork Avenue Hickory Hills, IL 60457 Cook County Contact: Danny 708/430-2955
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Gasoline - Premium	6,000	Currently in use	Federal
7	Diesel Fuel	6,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection

Summary of Work

Remove all mechanical leak detectors and install Veeder Root Electronic Line Leak Detectors on tanks 5, 6 & 7.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Big Daddy Pump & Compliance
301 Main St Unit 105
Antioch, IL 60073

Contact Person: Billy Umphrey
Phone: 352/901-4467
Email: billy@bigdaddypump.com
Contractor License # IL002457 Exp. 12/2/2024

Sincerely,

A handwritten signature in dark ink that reads "Shelly Bradley". The script is cursive and fluid, with the first name "Shelly" and last name "Bradley" clearly legible.

Shelly Bradley