



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2001734
Permit #: 00482-2024UPG
Request Rec'd: 04/29/2024
Approval Date: 04/29/2024 DS
Permit Expires: 10/29/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Ramar Land Corp 600 Gilian Rd. Wilmington, OH 45177 (None) County Contact: Stan Richards 800/543-5589	FACILITY - name and address where tanks are located: Greenwood Motor Lines, Inc. d/b/a R & L Carriers, Inc. 375 2nd Street at Berkeley Elgin, IL 60120 Kane County Contact: T 847/744-3840
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
10	Dyed Diesel	3,000	Currently in use	Federal

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated in Double Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispensers on the Permit

Dispenser	Action
4 Off Road Diesel	Sump / Sensors Changing

Dispenser 4 Off Road Diesel Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Summary of Work

This permit is to deregulate the UDC sensor for Tank #10, Dispenser #4. The dispenser is a European safe suction system. The sensor will remain for customer safety, but the sensor will be unregulated and not have positive shutdown.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: yvonne@crownetank.com Contractor License # IL002345 Exp. 5/16/2024

Sincerely,

Daniel G. Starks

Daniel Starks